

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1501:101 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** \*Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410  
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

**DESIGN:** Models 2453BSA-15-R, -30-R, -60-R, -15/75-R and -110-R adapter plate strobe lights. Unit consists of a separately listed strobe light mounted on an adapter plate. It is designed to allow an add-on of GS Building Systems' Model 439 Series bell (CSFM Listing No. 7135-1388:110). Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Candela:	-15: 15cd -30: 30cd -60: 60cd -15/75: 15/75cd -110: 110cd
Electrical:	20 - 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, candela/electrical rating and UL label.

**APPROVAL:** Listed as an adapter plate with strobe light for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired and for indoor use only.

**XLF:** 7125-1388:209

\*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager